

The attached list of self-contained meter sockets and enclosures has been approved for use in the service areas served by the utilities of the Meter Equipment Group. Approval is based on the unit's compliance with the MEG specifications, particularly U.L. listing, sealing requirements, bypass characteristics, and certain operational concerns. The MEG makes no claims regarding nameplate ratings or load side attachments beyond the sealed portion of the meter socket. We recommend that all units be used as intended by the manufacturer. All additional data is supplied for informational purposes only.

NOTES:

- A. All commercial or three phase applications require a unit with an approved bypass device. (Configuration 3, 4 or 5)
- B. All sockets are listed as their maximum socket amperage. 320/400 Amp enclosures are listed as 400 Amp maximum and 480/600 Amp enclosures are listed as 600 Amp maximum.
- C. Aluminum enclosures are recommended in salt spray areas.
- D. Sealing rings (ring-type sockets) along with all lugs/connectors (line and load side) are considered to be part of the meter enclosure. The customer/contractor is thereby responsible for furnishing these items. Please contact your utility representative to determine the proper size lugs/connectors. The sealing ring must be a captive-screw type equivalent to ABB #01L0028G02, Milbank MR-4/A3068, Landis & Gyr #9738-8002, or Ekstrom 10-9090.
- E. The "configuration" refers to the various meter connecting arrangements used to accommodate the utility meter. These configurations are described below:

SELF CONTAINED CONFIGURATIONS

DESCRIPTION & TYPICAL APPLICATION

1	Residential - 4 Terminal Socket, Single Phase, 3 Wire
2	Residential - 5 Terminal Socket, Network, 3 Wire
3	Residential/Commercial - 4 Terminal Socket (w/Bypass), Single Phase, 3 Wire
3a	Residential/Commercial - 5 Terminal Socket (w/Bypass), Network, 3 Wire
3b	Residential/Commercial - 5 Terminal socket (w/Bypass), Neutral can be isolated for 3-phase, 3-wire applications.
4	Commercial - 7 Terminal Socket (w/Bypass), Three Phase, 4 Wire
*5	Residential/Commercial – K7 Base (w/Bypass), Single Phase (FPL Only), Three Phase or Network, 3 or 4 Wire

***K7 Three Phase K-Base applications are ONLY allowed at FPL
(GULF, DUKE, OGE and TECO do not allow any K-base installations)**

Participants:





Participants: DUKE, FPL, GULF, OGE, TECO

Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Durham	100	UTZ-6R1131C-FL		1	Ov/Un	6	4	N	1
Durham	100	UTZ-6R1131C-FLCH		1	Ov/Un	6	4	N	1
Durham	100	UTZ-xR1121C-FL	(x=2-5)	1	Ov/Un	2-5	4	N	1
Durham	125	UATZ-RS101C-FL		1	Ov/Un	1	4	N	1 AI
Durham	125	UTZ-RS101C-FL		1	Ov/Un	1	4	N	1
Durham	200	UAT-H4203x-FL	(x=B or T)	1	Over	1	4	Y	1 AI
Durham	200	UAT-H4213x-FL	(x=C or U)	1	Ov/Un	1	4	Y	1 AI
Durham	200	UAT-H5203x-FL	(x=B or T)	1	Over	1	5	Y	3,3a,3b AI
Durham	200	UAT-H5213x-FL	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b AI
Durham	200	UAT-H7203x-FL	(x=B or T)	3	Over	1	7	Y	4 AI
Durham	200	UAT-H7213x-FL	(x=C or U)	3	Ov/Un	1	7	Y	4 AI
Durham	200	UAT-RS202B-FL		1	Over	1	4	N	1 AI
Durham	200	UAT-RS212C-FL		1	Ov/Un	1	4	N	1 AI
Durham	200	UAT-RS213A-FL		1	Under	1	4	N	1 AI
Durham	200	UAT-RS213C-FL		1	Ov/Un	1	4	N	1 AI
Durham	200	UAT-RS223A-FL		1	Under	1	4	N	1 AI
Durham	200	UT-4R2352U-FL		1	Ov/Un	4	4	N	1
Durham	200	UT-H4203x-FL	(x=B or T)	1	Over	1	4	Y	1
Durham	200	UT-H4213x-FL	(x=C or U)	1	Ov/Un	1	4	Y	1
Durham	200	UT-H5203x-FL	(x=B or T)	1	Over	1	5	Y	3,3a,3b
Durham	200	UT-H5213x-FL	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b
Durham	200	UT-H7203x-FL	(x=B or T)	3	Over	1	7	Y	4
Durham	200	UT-RS213A-FL		1	Under	1	4	N	1
Durham	200	UT-RS213C-FL		1	Ov/Un	1	4	N	1
Durham	200	UT-RS223A-FL		1	Under	1	4	N	1
Durham	200	UT-xR2332U-FL	(x=2-3)	1	Ov/Un	2-3	4	N	1
Durham	200	UT-xR2392UU-FL	(x=5-6)	1	Ov/Un	5-6	4	N	1
Durham	400	1008836		1	Ov/Un	1	4	Y	1
Durham	400	1008837		1	Ov/Un	1	4	Y	1 AI
Durham	400	UAT-H4300T-FL		1	Over	1	4	Y	1 AI
Durham	400	UAT-H5300T-FL		1	Over	1	5	Y	3,3a,3b AI
Durham	400	UAT-H5330U-FL		1	Ov/Un	1	5	Y	3,3a AI
Durham	400	UAT-H7300T-FL		3	Over	1	7	Y	4 AI
Durham	400	UAT-H7330U-FL		3	Ov/Un	1	7	Y	4 AI
Durham	400	UT-H4300T-FL		1	Over	1	4	Y	1
Durham	400	UT-H5300T-FL		1	Over	1	5	Y	3,3a,3b
Durham	400	UT-H5330U-FL		1	Ov/Un	1	5	Y	3,3a,3b
Durham	400	UT-H7300T-FL		3	Over	1	7	Y	4
Durham	400	UT-H7330U-FL		3	Ov/Un	1	7	Y	4



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Eaton B-Line	100	ECCB10L25A3xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3a
Eaton B-Line	100	ECCB10L27A3xx1F (xx=GR, AL, SS)	3	OH/UG	1	7	Y	4
Eaton B-Line	100	ENCB10L25A3xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	N	1,2
Eaton B-Line	100	HEC10432Cxx1F (xx=GR, AL, SS)	1	OH/UG	2	4	Y	3
Eaton B-Line	100	HEC10433Cxx1F (xx=GR, AL, SS)	1	OH/UG	3	4	Y	3
Eaton B-Line	100	HEN10432Lxx1F (xx=GR, AL, SS)	1	OH/UG	2	4	N	3
Eaton B-Line	100	HEN10433Lxx1F (xx=GR, AL, SS)	1	OH/UG	3	4	N	3
Eaton B-Line	100	HEN10434Lxx1F (xx=GR, AL, SS)	1	OH/UG	4	4	N	3
Eaton B-Line	100	HEN10435Lxx1F (xx=GR, AL, SS)	1	OH/UG	5	4	N	3
Eaton B-Line	100	HEN10436Lxx1F (xx=GR, AL, SS)	1	OH/UG	6	4	N	3
Eaton B-Line	125	EC12L53xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3,3a,3b
Eaton B-Line	125	EN12L41xx1F (xx=GR, AL, SS)	1	OH	1	4	N	1
Eaton B-Line	125	EN12L42xx1F (xx=GR, AL, SS)	1	UG	1	4	N	1
Eaton B-Line	125	EN12L43xx1F (xx=GR, AL, SS)	1	OH/UG	1	4	N	1
Eaton B-Line	125	EN12L51xx1F (xx=GR, AL, SS)	1	OH	1	5	N	1,2
Eaton B-Line	125	EN12L52xx1F (xx=GR, AL, SS)	1	UG	1	5	N	1,2
Eaton B-Line	125	EN12L53xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	N	1,2
Eaton B-Line	125	VENMP12432Lxx1F (xx=GR, AL, SS)	1	OH/UG	2	4	N	3
Eaton B-Line	125	VENMP12433Lxx1F (xx=GR, AL, SS)	1	OH/UG	3	4	N	3
Eaton B-Line	125	VENMP12434Cxx1F (xx=GR, AL, SS)	1	OH/UG	4	4	N	3
Eaton B-Line	125	VENMP12435Cxx1F (xx=GR, AL, SS)	1	OH/UG	5	4	N	3
Eaton B-Line	125	VENMP12436Cxx1F (xx=GR, AL, SS)	1	OH/UG	6	4	N	3
Eaton B-Line	150	ENCB15L25A3xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	N	1,2
Eaton B-Line	200	EL20L53xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3,3a
Eaton B-Line	200	EL20L73xx1F (xx=GR, AL, SS)	3	OH/UG	1	7	Y	4
Eaton B-Line	200	ELCB20L25A3xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3,3a
Eaton B-Line	200	ELCB20L27A3xx1F (xx=GR, AL, SS)	3	OH/UG	1	7	Y	4
Eaton B-Line	200	EN20L41xx1F (xx=GR, AL, SS)	1	OH	1	4	N	1
Eaton B-Line	200	EN20L42xx1F (xx=GR, AL, SS)	1	UG	1	4	N	1
Eaton B-Line	200	EN20L43xx1F (xx=GR, AL, SS)	1	OH/UG	1	4	N	1
Eaton B-Line	200	EN20L51xx1F (xx=GR, AL, SS)	1	OH	1	5	N	1,2
Eaton B-Line	200	EN20L52xx1F (xx=GR, AL, SS)	1	UG	1	5	N	1,2
Eaton B-Line	200	EN20L53xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	N	3,3a,3b
Eaton B-Line	200	ENCB20L25A3xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	N	1,2
Eaton B-Line	200	HEL20432Cxx1F (xx=GR, AL, SS)	1	OH/UG	2	4	Y	3
Eaton B-Line	200	HEL20433Cxx1F (xx=GR, AL, SS)	1	OH/UG	3	4	Y	3
Eaton B-Line	200	HEL20434Cxx1F (xx=GR, AL, SS)	1	OH/UG	4	4	Y	3
Eaton B-Line	200	HEL20435Cxx1F (xx=GR, AL, SS)	1	OH/UG	5	4	Y	3
Eaton B-Line	200	HEL20436Cxx1F (xx=GR, AL, SS)	1	OH/UG	6	4	Y	3



Approved Metering Equipment Enclosure List

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Eaton B-Line	200	HEL20732Cxx1F (xx=GR, AL, SS)	3	OH/UG	2	7	Y	4
Eaton B-Line	200	HEL20733Cxx1F (xx=GR, AL, SS)	3	OH/UG	3	7	Y	4
Eaton B-Line	200	HEL20734Cxx1F (xx=GR, AL, SS)	3	OH/UG	4	7	Y	4
Eaton B-Line	200	HEL20735Cxx1F (xx=GR, AL, SS)	3	OH/UG	5	7	Y	4
Eaton B-Line	200	HEL20736Cxx1F (xx=GR, AL, SS)	3	OH/UG	6	7	Y	4
Eaton B-Line	200	VENMP20432Lxx1F (xx=GR, AL, SS)	1	OH/UG	2	4	N	3
Eaton B-Line	200	VENMP20433Lxx1F (xx=GR, AL, SS)	1	OH/UG	3	4	N	3
Eaton B-Line	200	VENMP20434Cxx1F (xx=GR, AL, SS)	1	OH/UG	4	4	N	3
Eaton B-Line	200	VENMP20435Cxx1F (xx=GR, AL, SS)	1	OH/UG	5	4	N	3
Eaton B-Line	200	VENMP20436Cxx1F (xx=GR, AL, SS)	1	OH/UG	6	4	N	3
Eaton B-Line	400	EL32T53xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3,3a
Eaton B-Line	400	EL32T56xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3,3a
Eaton B-Line	400	EL32T75xx1F (xx=GR, AL, SS)	3	OH/UG	1	7	Y	4
Eaton B-Line	400	EL32T76xx1F (xx=GR, AL, SS)	3	OH/UG	1	7	Y	4
Eaton B-Line	400	ELCB32C25A5xx1F (xx=GR, AL, SS)	1	OH/UG	1	5	Y	3,3a
Eaton-Cutler Hammer	100	MB1224B100BTS	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	100	UATZ-xR1121CFLCH (x=2-5)	1	Ov/Un	2-5	4	N	1 AI
Eaton-Cutler Hammer	100	UTZ-xR1121C-FLCH (x=2-5)	1	Ov/Un	2-5	4/5	N	1,2
Eaton-Cutler Hammer	125	1MMx12RP, RCP, RRLP or RRLCP (x=3-6)	1	Ov/Un	3-6	4	N	1
Eaton-Cutler Hammer	125	1MPx124RP, RRLP or RRLCP (x=3-4)	1	Ov/Un	3-4	4	N	1
Eaton-Cutler Hammer	125	1MPx126RP, RRLP or RRLCP (x=5-6)	1	Ov/Un	5-6	4	N	1
Eaton-Cutler Hammer	125	3MMx12RP,RCP,RRLP,RRLCP,R12P or R12RLP (x=2-6)	1	Ov/Un	2-6	4	N	1
Eaton-Cutler Hammer	125	CHR (POWER OUTLET PANEL)	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	125	CMB24L125BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	125	MB24L125BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	125	UATZ-RS101C-FLCH	1	Ov/Un	1	4	N	1 AI
Eaton-Cutler Hammer	125	UT-RS101xE (x=B,C)	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	125	UTZ-RS101C-FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	CMB88B150BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	CMBB150BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	MB816B150BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	MBB150BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	150	MBT48B150BTS	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	1MMx20RRLP or RRLCP (x=3-4)	1	Ov/Un	3-4	4	N	3
Eaton-Cutler Hammer	200	1MP2204RP, RRLP or RRLCP	1	Ov/Un	2	4	N	1
Eaton-Cutler Hammer	200	1MPx206RP, RRLP or RRLCP (x=3-6)	1	Ov/Un	3-6	4	N	1
Eaton-Cutler Hammer	200	3MMx20RP, RCP,RRLP,RRLCP,R12P or R12RLP (x=2-5)	1	Ov/Un	2-5	4	N	3
Eaton-Cutler Hammer	200	CMB1212B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB1212L200BTS	1	Ov/Un	1	4	N	1



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Eaton-Cutler Hammer	200	CMB1212P200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB2424B200BTS	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB2436B200BTS	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB4242B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMB88B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMBB200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	CMBP200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB1212L200BTS	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB1212L200B TSA	1	Ov/Ln	1	4	N	1 AI
Eaton-Cutler Hammer	200	MB2040B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB2040P200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB4040B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB48B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB816B200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MB816P200BTS FLCH or BTSCU FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MBB200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MBP200BTS FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	MBT48B200BTS	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UAT-4R2352U FLCH	1	Ov/Un	4	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-H4203x-FLCH (x=B or T)	1	Over	1	4	Y	1 AI
Eaton-Cutler Hammer	200	UAT-H5203x-FLCH (x=B or T)	1	Over	1	5	Y	3,3a,3b AI
Eaton-Cutler Hammer	200	UAT-H7203x-FLCH (x=B or T)	3	Over	1	7	Y	4 AI
Eaton-Cutler Hammer	200	UAT-RS202B-FLCH	1	Over	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS212C-FLCH	1	Ov/Un	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS213A-FLCH	1	Under	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS213C-FLCH	1	Ov/Un	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-RS223A-FLCH	1	Under	1	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-xR2332U-FLCH (x=2-3)	1	Ov/Un	2-3	4	N	1
Eaton-Cutler Hammer	200	UATxR2392UU FLCH (x=5-6)	1	Ov/Un	5-6	4	N	1 AI
Eaton-Cutler Hammer	200	UAT-y4213x-FLCH (y=E or H, where x=C or U)	1	Ov/Un	1	4	Y	1 AI
Eaton-Cutler Hammer	200	UAT-y5213x-FLCH (y=E or H, where x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b AI
Eaton-Cutler Hammer	200	UAT-y7213x-FLCH (y=E or H, where x=C or U)	3	Ov/Un	1	7	Y	4 AI
Eaton-Cutler Hammer	200	UT-4R2352U-FLCH	1	Ov/Un	4	4	N	1
Eaton-Cutler Hammer	200	UT-RS202B-FLCH	1	Over	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS212C-FLCH	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS213A-FLCH	1	Under	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS213CE	1	Ov/Un	1	4	N	1
Eaton-Cutler Hammer	200	UT-RS213C-FLCH	1	Ov/Un	1	4/5	N	1, 2
Eaton-Cutler Hammer	200	UT-RS223A-FLCH	1	Under	1	4	N	1



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Eaton-Cutler Hammer	200	UT-xR2332U-FLCH	(x=2-3)	1	Ov/Un	2-3	4	N	1
Eaton-Cutler Hammer	200	UT-xR2392UU-FLCH	(x=5-6)	1	Ov/Un	5-6	4	N	1
Eaton-Cutler Hammer	200	UT-y4203x-FLCH	(y=E or H, where x=B or T)	1	Over	1	4	Y	1
Eaton-Cutler Hammer	200	UT-y4213x-FLCH	(y=E or H, where x=C or U)	1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	200	UT-y5203x-FLCH	(y=E or H, where x=B or T)	1	Over	1	5	Y	3,3a,3b
Eaton-Cutler Hammer	200	UT-y5213x-FLCH	(y=E or H, where x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b
Eaton-Cutler Hammer	200	UT-y7203x-FLCH	(y=E or H, where x=B or T)	3	Over	1	7	Y	4
Eaton-Cutler Hammer	200	UT-y7213x-FLCH	(where y=E or H, x=C or U)	3	Ov/Un	1	7	Y	4
Eaton-Cutler Hammer	225	35MMx20R12 or R12C	(x=1-4)	1	Ov/Un	1-4	5	Y	3,3a
Eaton-Cutler Hammer	225	37MMx20R12 or R12C	(x=1-4)	3	Ov/Un	1-4	7	Y	4
Eaton-Cutler Hammer	400	1008836CH		1	Ov/Un	1	4	Y	1 AI
Eaton-Cutler Hammer	400	1008837CH		1	Ov/Un	1	4	Y	1 AI
Eaton-Cutler Hammer	400	1011619CH		1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	400	35MM140R1240		1	Under	1	5	Y	3
Eaton-Cutler Hammer	400	35MM240R1240		1	Under	2	5	Y	3
Eaton-Cutler Hammer	400	37MM140R1240		3	Under	1	7	Y	4
Eaton-Cutler Hammer	400	37MM240R1240		3	Under	1	7	Y	4
Eaton-Cutler Hammer	400	CG1212P400BSL		1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	CG404242SHL		1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	CG40SHL		1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	HP404040SHL		1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	HP40SHL		1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	HP816Px00BSL	(x = 3 or 4)	1	Under	1	4	Y	3
Eaton-Cutler Hammer	400	HPCx046SHLG	(x= 3 or 4)	1	Ov/Un	1	4	y	3
Eaton-Cutler Hammer	400	HPCx0SHL	(x= 3 or 4)	1	Ov/Un	1	4	y	3
Eaton-Cutler Hammer	400	UAT-H4300T-FLCH		1	Over	1	4	Y	1 AI
Eaton-Cutler Hammer	400	UAT-H5300T-FLCH		1	Over	1	5	Y	3,3a,3b AI
Eaton-Cutler Hammer	400	UAT-H5330U-FLCH		1	Ov/Un	1	5	Y	3,3a,3b AI
Eaton-Cutler Hammer	400	UAT-H7300T-FLCH		3	Over	1	7	Y	4 AI
Eaton-Cutler Hammer	400	UAT-H7330U-FLCH		3	Ov/Un	1	7	Y	4 AI
Eaton-Cutler Hammer	400	UT-H4300T-FLCH		1	Over	1	4	Y	1
Eaton-Cutler Hammer	400	UTH43068TFLCH		1	Ov/Un	1	4	Y	1
Eaton-Cutler Hammer	400	UT-H5300T-FLCH		1	Over	1	5	Y	3,3a,3b
Eaton-Cutler Hammer	400	UT-H5330U-FLCH		1	Ov/Un	1	5	Y	3,3a,3b
Eaton-Cutler Hammer	400	UT-H7300T-FLCH)	3	Over	1	7	Y	4
Eaton-Cutler Hammer	400	UT-H7330U-FLCH		3	Ov/Un	1	7	Y	4
Eaton-Cutler Hammer	400	UTH73368UFLCH		3	Ov/Un	1	7	Y	4
Eaton-Cutler Hammer	600	CH9526K7 (Requires Ridged Lugs)	FPL ONLY	3	Ov/Un	1	7	Y	5
Eaton-Cutler Hammer	600	CH9527K7 (Requires Ridged Lugs)	FPL ONLY	3	Ov/Un	1	7	Y	5 AI



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Elec.Prod.	100	RVP-xxxx-FPL	1	Under	1	4	N	1
Elec.Prod.	200	MHP-xxxx-FPL	1	Under	1	4	N	1
Emerson	125	MESBGFXLW11FBZ1	1	Under	1	5	Y	3a
Emerson	125	MESBGFXLW11FBZ1P	1	Under	1	5	Y	3a
Emerson	125	MESBGFXLW11KBZ1	1	Under	1	5	Y	3a
Emerson	125	MESBGFXLW11KBZ1P	1	Under	1	5	Y	3a
Emerson	200	MESBAATLW11FBZ1	1	Under	1	5	Y	3a
Emerson	200	MESBAATLW11FBZ1P	1	Under	1	5	Y	3a
Emerson	200	MESBAATLW11KBZ1	1	Under	1	5	Y	3a
Emerson	200	MESBAATLW11KBZ1P	1	Under	1	5	Y	3a
General Electric	(2) 150	TSDR830USCU	1	Under	1	4/5	Y	1,2
General Electric	100	TM10RMCFMG	1	Ov/Un	1	4	N	1
General Electric	125	TM12RMCFMG	1	Ov/Un	1	4	N	1
General Electric	125	TMM2212RF	1	Ov/Un	2	4	N	1
General Electric	125	TMM4x12RF (x=3-4)	1	Under	3-4	4	N	1
General Electric	125	TMM6x12RF (x=5-6)	1	Under	5-6	4	N	1
General Electric	125	TMMR2212RF	1	Ov/Un	2	4/5	N	1,2
General Electric	125	TMMR4x12RF (x=3-4)	1	Under	3-4	4/5	N	1,2
General Electric	125	TMMR6x12RF (x=5-6)	1	Under	5-6	4/5	N	1,2
General Electric	125	TMPR12x12RF (x=2-6)	1	Ov/Un	2-6	5	N	2
General Electric	125	TMPR8x12RF (x=2-6)	1	Ov/Un	2-6	4	N	1,2
General Electric	125	TMPR8x12RF (x=2-6)	1	Ov/Un	2-6	5	N	2
General Electric	150	TM15RMCFMG	1	Ov/Un	1	4	N	1
General Electric	150	TSMF415CSFL	1	Ov/Un	1	4/5	N	1,2
General Electric	150	TSMF815CSFL	1	Ov/Un	1	4/5	N	1,2
General Electric	150	TSMR415CSFLFMG	1	Ov/Un	1	5	N	2
General Electric	150	TSMR815CSFLFMG	1	Ov/Un	1	5	N	2
General Electric	200	TM20RMCFMG	1	Ov/Un	1	4	N	1
General Electric	200	TMM6x20RF (x=3-4)	1	Under	3-4	4	N	1
General Electric	200	TMMR4220RF	1	Under	2	5	N	2
General Electric	200	TMMR6x20RF (x=3-6)	1	Under	3-6	5	N	2
General Electric	200	TMP12x20RF (x=2-4)	1	Ov/Un	2-4	4	N	1
General Electric	200	TMP8x20RF (x=3-4)	1	Ov/Un	3-4	4	N	1
General Electric	200	TMPR12x20RF (x=4-5)	1	Ov/Un	4-5	5	N	2
General Electric	200	TMPR8x20RF (x=2-5)	1	Ov/Un	2-5	5	N	2
General Electric	200	TSLR1220FSAL	1	Ov/Un	1	4/5	N	1,2
General Electric	200	TSMF420CSFL	1	Ov/Un	1	4/5	N	1,2
General Electric	200	TSMF820CSFL	1	Ov/Un	1	4/5	N	1,2
General Electric	200	TSMR2020CSCUFMG	1	Ov/Un	1	4/5	N	1,2



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
General Electric	200	TSMRx20CSFLFMG (x = 4, 8)	1	Ov/Un	1	4/5	N	1,2
General Electric	225	TMPR12x22R (x=1-4)	1	Ov/Un	1-4	5	Y	3,3a
General Electric	225	TMPR312x22RF (x=1-4)	3	Ov/Un	1-4	7	Y	4
General Electric	400	TMPR12x40RB (x=1-2)	1	Ov/Un	1-2	5	N	3, 3a
General Electric	400	TMPR312x40RB (x=1-2)	3	Ov/Un	1-2	7	Y	4
General Electric	400	TSDR840UFCU	1	Under	1	4/5	Y	1,2
General Electric	400	TSDR840USCU	1	Under	1	4/5	Y	1,2
Midwest	125	UTZ-RS101CFLMEP	1	Ov/Un	1	4	N	1
Midwest	150	R158CR2TLFMG	1	Ov/Un	1	4	N	1
Midwest	200	MPx00S0FMG (x=1-4)	1	Under	1-4	4/5	N	1,2 Al
Midwest	200	MPx00S1FMG (x=1-4)	1	Under	1-4	4/5	N	1,2 Al
Midwest	200	MPx20B0FMG (x=1-4)	1	Under	1-4	4/5	N	1,2 Al
Midwest	200	MPx20B1FMG (x=1-4)	1	Under	1-4	4/5	N	1,2 Al
Midwest	200	R208CR2TLFMG	1	Ov/Un	1	4	N	1
Midwest	200	R256EB118FMG	1	Ov/Un	1	4	N	1, Al
Midwest	200	R256EB1FMG	1	Ov/Un	1	4	N	1
Midwest	200	R256EB1NFMG	1	Ov/Un	1	4	N	1
Midwest	200	UT-4R2352UFLMEP	1	Ov/Un	4	4	N	1
Midwest	200	UT-H5213x-FLMEP (x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b
Midwest	200	UT-H7213x-FLMEP (where x=C or U)	3	Ov/Un	1	7	Y	4
Midwest	200	UT-xR2332UFLMEP (x=2-3)	1	Ov/Un	2-3	4	N	1
Midwest	200	UTxR2392UUFLMEP (x=5-6)	1	Ov/Un	1	4	N	1
Midwest	400	RS45524CFMG	1	Under	1	4/5	Y	1,2
Midwest	400	UT-H4300T-FLMEP	1	Over	1	4	Y	1
Midwest	400	UT-H5330U-FLMEP	1	Ov/Un	1	5	Y	3,3a
Milbank	100	U349y-XL-HSP (y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	100	U513y-O-100P-FMG (y=6-7)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	100	U513y-O-100S-FMG (y=6-7)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	100	U5842-RL-100-HSP	1	Over	1	4	N	1
Milbank	100	U6266-XTL-100-HSP	1	Ov/Un	1	4/5	N	1,2
Milbank	100	UAP349y-XL-HSP (y=2-6)	1	Ov/Un	2-6	4/5	N	1,2 Al
Milbank	125	U285y-X-HSP (y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	125	U3505-XL-HSP	1	Ov/Un	1	5	Y	3,3a
Milbank	125	U3505-XL-TG-HSP	1	Ov/Un	1	5	Y	3,3a
Milbank	125	U3506-XL-TG-HSP	3	Ov/Un	1	7	Y	4
Milbank	125	U513y-O-125P-FMG (y=6-7)	1	Under	1-2	4/5	N	1,2
Milbank	125	U513y-O-125S-FMG (y=6-7)	1	Under	1-2	4/5	N	1,2
Milbank	125	U8435-XL-TG-HSP	1	Ov/Un	1	4/5	N	1,2
Milbank	125	UAP3505-XL-TG-HSP	1	Ov/Un	1	5	Y	3,3a Al



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Milbank	125	UAP3506-XL-TG-HSP		3	Ov/Un	1	7	Y	4 AI
Milbank	125	UAP8435-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2 AI
Milbank	150	U123y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	150	U3312-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	150	U513y-O-150P-FMG	(y=6-7)	1	Under	1-2	4/5	N	1,2
Milbank	150	U513y-O-150S-FMG	(y=6-7)	1	Under	1-2	4/5	N	1,2
Milbank	150	U5842-RL-150-HSP		1	Over	1	4	N	1
Milbank	150	U6266-XTL-150-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	150	UAP123y-X-HSP	(y=2-3)	1	Ov/Un	2-3	4/5	N	1,2 AI
Milbank	200	CP3B52519R22SSSGSP1		3	Un-Ped	1	7	Y	4 SS
Milbank	200	U125Y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	200	U1980-O-HSP		1	Under	1	4/5	N	1,2
Milbank	200	U273y-XT-HSP	(y=2-6)	3	Ov/Un	2-6	7	Y	4
Milbank	200	U286y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	N	1,2
Milbank	200	U287y-XT-HSP	(y=2-6)	1	Ov/Un	2-6	5	Y	3,3a
Milbank	200	U3296-X-HSP		1	Ov/Un	1	5	Y	3,3a,3b
Milbank	200	U3306-X-HSP		3	Ov/Un	1	7	Y	4
Milbank	200	U3850-XL-TG-HSP-PL		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U5136-O-yyy-FMG	(yyy=41,55,75,332,552)	1	Un-Ped	1	4/5	N	1,2
Milbank	200	U5137-O-yyy-FMG	(yyy=41,55,75,332,552)	1	Un-Ped	2	4/5	N	1,2
Milbank	200	U513y-O-200P-FMG	(y=6-7)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U513y-O-200S-FMG	(y=6-7)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U513y-O-FMG	(y=6-7)	1	Un-Ped	1-2	4/5	N	1,2
Milbank	200	U5842-RL-200-HSP		1	Over	1	4	N	1
Milbank	200	U6266-XTL-200-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U7021-RL-TG-HSP		1	Over	1	4/5	N	1,2
Milbank	200	U7040-O-TG-HSP		1	Under	1	4	N	1,2
Milbank	200	U7040-XL-TG-HSP		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U7043-XL-TG		1	Ov/Un	1	4/5	N	1,2
Milbank	200	U9550-RRL-QG-HSP		1	Over	1	5	Y	3,3a,3b
Milbank	200	U9551-X-QG-HSP		1	Ov/Un	1	5	Y	3,3a,3b
Milbank	200	U9700-RRL-QG-HSP		3	Over	1	7	Y	4
Milbank	200	U9701-X-QG-HSP		3	Ov/Un	1	7	Y	4
Milbank	200	U9801-X-QG-HSP		1	Ov/Un	1	4	Y	1,2
Milbank	200	UAP125y-X-HSP	(y=2-6)	1	Ov/Un	2-6	4/5	Y	1,2 AI
Milbank	200	UAP1980-O-HSP		1	Under	1	4/5	N	1,2 AI
Milbank	200	UAP3296-X-HSP		1	Ov/Un	1	5	Y	3,3a,3b AI
Milbank	200	UAP3306-X-HSP		3	Ov/Un	1	7	Y	4 AI
Milbank	200	UAP5024-XL		1	Ov/Un	1	4	N	1 AI



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Milbank	200	UAP5024-XL-FMG	1	Ov/Un	1	4	N	1 AI
Milbank	200	UAP7021-RL-TG-HSP	1	Over	1	4/5	N	1,2 AI
Milbank	200	UAP7040-O-TG-HSP	1	Under	1	4/5	N	1,2 AI
Milbank	200	UAP7040-XL-TG-HSP	1	Ov/Un	1	4/5	N	1,2 AI
Milbank	200	UAP9550-RRL-QG-HSP	1	Over	1	5	Y	3,3a,3b AI
Milbank	200	UAP9551-X-QG-HSP	1	Ov/Un	1	5	Y	3,3a,3b AI
Milbank	200	UAP9700-RRL-QG-HSP	3	Over	1	7	Y	4 AI
Milbank	200	UAP9701-X-QG-HSP	3	Ov/Un	1	7	Y	4 AI
Milbank	400	U1129-O-K3L-K2L-HSP	1	Under	1	4/5	Y	3,3a
Milbank	400	U2120-O-HSP	3	Ov/Un	1	7	Y	4
Milbank	400	U2120-X-HSP	3	Ov/Un	1	7	Y	4
Milbank	400	U2124-O-HSP	1	Under	1	4	Y	3
Milbank	400	U3313-X-HSP	1	Ov/Un	1	5	Y	3,3a
Milbank	400	U3566-X-HSP	3	Ov/Un	1	7	Y	4
Milbank	400	U3949-X-HSP	1	Over	1	5	Y	3,3a
Milbank	400	U4363-X-HSP	1	Over	1	4	Y	3
Milbank	400	U5864-X-HSP	1	Ov/Un	1	5	Y	3, 3a
Milbank	400	U5890-X-2/150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U5890-X-2/200-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U5890-X-200-150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U5891-X-2/150-MLK-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U5891-X-2/200-MLK-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U6267-X-2/100-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U6267-X-2/150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U6267-X-2/200-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U6267-X-200 -150-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U6272-X-HSP	1	Ov/Un	1	4	Y	3
Milbank	400	U6273-X-HSP	1	Over	1	4	Y	3
Milbank	400	UAP2124-O-HSP	1	Under	1	4	Y	4 AI
Milbank	400	UAP3313-X-HSP	1	Ov/Un	1	5	Y	3,3a AI
Milbank	400	UAP3566-X-HSP	3	Ov/Un	1	7	Y	4 AI
Milbank	400	UAP3949-X-HSP	1	Over	1	5	Y	3,3a AI
Milbank	400	UAP5864-X-HSP	1	Ov/Un	1	5	Y	3, 3a AI
Milbank	400	UAP6272-X-HSP	1	Ov/Un	1	4	Y	3 AI
Milbank	600	U4667-X-8528 (Req. Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5
Milbank	600	U4667-XT-9526(Requires Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5
Milbank	600	UA4667-X-8529 (Req. Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5 AI
Milbank	600	UA4667-XT-9527(Requires Ridged Lugs) FPL ONLY	3	Ov/Un	1	7	Y	5 AI
Murray	100	RJ103AXF	1	Over	1	4	N	1



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Murray	125	JA1224B1125	1	Ov/Un	1	4/5	N	1,2
Murray	150	JA0408B1150T or RT	1	Ov/Un	1	4	N	1
Murray	150	JA0816B1150CT or RCT	1	Ov/Un	1	4	N	1
Murray	150	JA0816B1150TH	1	Ov/Un	1	4/5	N	1,2
Murray	150	JA2040B1150	1	Ov/Un	1	4/5	N	1,2
Murray	150	JA2040B1150RC	1	Ov/Un	1	4	N	1
Murray	150	JA204LS	1	Ov/Un	1	4/5	N	1,2
Murray	150	JC0202B1150	1	Ov/Un	1	4/5	N	1,2
Murray	200	JA0408B1200T or RT	1	Ov/Un	1	4	N	1
Murray	200	JA0606L1200R or RA	1	Ov/Un	1	4/5	N	1, 1 AI
Murray	200	JA0816B1200CT or RCT	1	Ov/Un	1	4	N	1
Murray	200	JA0816B1200TH	1	Ov/Un	1	4/5	N	1,2
Murray	200	JA2040B1200	1	Ov/Un	1	4/5	N	1,2
Murray	200	JA2040B1200RC	1	Ov/Un	1	4	N	1
Murray	200	JA204TS	1	Ov/Un	1	4/5	N	1,2
Murray	200	JC0202B1200	1	Ov/Un	1	4/5	N	1,2
Murray	200	RB103AR	1	Ov/Un	1	4/5	N	1,2
Murray	200	RH173CRF	1	Ov/Un	1	5	Y	3,3a
Murray	200	RH173GRF	3	Ov/Un	1	7	Y	4
Murray	200	RS103AVF	1	Under	1	4/5	N	1,2
Murray	200	RS103AXF	1	Over	1	4	N	1
Murray	400	JA0816B1350RLTM	1	Ov/Un	1	4/5	Y	1,2
Murray	400	JA0816B1400RLTM	1	Ov/Un	1	4/5	Y	1,2
Murray	400	JC0404L1400RLM	1	Ov/Un	1	4/5	Y	1,2
Murray	400	JC0408B1400RLTM	1	Ov/Un	1	4/5	Y	1,2
Siemens	125	MC1224B1125	1	Ov/Un	1	4/5	N	1,2
Siemens	125	SPxx11RJ (xx=22, 33, 44, 45, 46, 65, 66)	1	Ov/Un	2-6	4/5	N	1,2
Siemens	125	SUAT111-OGF	1	Over	1	4	N	1
Siemens	125	WMMx1125R (x=2-6)	1	Under	2-6	4/5	N	1,2
Siemens	125	WMMx2125RJ (x=2-6)	3	Under	2-6	5	N	2
Siemens	125	WP2211RJ	1	Mtr Ctr	2	5	N	2
Siemens	125	WP3311RJ	1	Mtr Ctr	3	5	N	2
Siemens	125	WP4X11RJ (x=4-6)	1	Mtr Ctr	4-6	5	N	2
Siemens	125	WP5411RJ	1	Mtr Ctr	4	5	N	2
Siemens	125	WP6x11RJ (x=5-6)	1	Mtr Ctr	5-6	5	N	2
Siemens	150	MC0408B1150T or RT	1	Ov/Un	1	4	N	1
Siemens	150	MC0408MB1150T	1	Ov/Un	1	4/5	N	1,2
Siemens	150	MC0816B1150CT or RCT	1	Ov/Un	1	4	N	1
Siemens	150	MC0816B1150RTH	1	Ov/Un	1	4/5	N	1,2



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Siemens	150	MC2040B1150	1	Ov/Un	1	4/5	N	1,2
Siemens	150	MC2040B1150RC	1	Ov/Un	1	4	N	1
Siemens	150	MM0202B1150	1	Ov/Un	1	4/5	N	1,2 St
Siemens	200	MC0408B1200T or RT	1	Ov/Un	1	4	N	1
Siemens	200	MC0408MB1200T	1	Ov/Un	1	4/5	N	1,2
Siemens	200	MC0606L1200R or RA	1	Ov/Un	1	4/5	N	1, 1 Al
Siemens	200	MC0816B1200CT or RCT	1	Ov/Un	1	4	N	1
Siemens	200	MC0816B1200RTH	1	Ov/Un	1	4/5	N	1,2
Siemens	200	MC2040B1200	1	Ov/Un	1	4/5	N	1,2
Siemens	200	MC2040B1200RC	1	Ov/Un	1	4	N	1
Siemens	200	MM0202B1200	1	Ov/Un	1	4/5	N	1,2 St
Siemens	200	MM0406L1200H	1	Ov/Un	1	4/5	N	1,2
Siemens	200	S40405-015F	1	Ov/Un	1	5	Y	3,3a
Siemens	200	S40407-015F	3	Ov/Un	1	7	Y	4
Siemens	200	SPxx12RJ (xx=42, 43, 44, 65, 66)	1	Ov/Un	2-6	4/5	N	1,2
Siemens	200	SUAT317-OGF	1	Over	1	4	N	1
Siemens	200	SUAT417-PGF	1	Under	1	4/5	N	1,2
Siemens	200	SUAT417-XGF	1	Ov/Un	1	4/5	N	1,2
Siemens	200	WMLx3200RJ (x=1-4)	3	Under	1-4	7	Y	4
Siemens	200	WMMx1225R (x=2-6)	1	Under	2-6	4/5	N	1,2
Siemens	200	WMMx2225RJ (x=2-6)	3	Under	2-6	5	N	2
Siemens	200	WP4x12RJ (x=2-4)	1	Mtr Ctr	2-4	4/5	N	1,2
Siemens	200	WP68612RJ	1	Mtr Ctr	6	4/5	N	1,2
Siemens	200	WP6x12RJ (x=4-6)	1	Mtr Ctr	4-6	4/5	N	1,2
Siemens	200	WP8612RJ	1	Mtr Ctr	6	4/5	N	1,2
Siemens	200	WPL10612RJ	1	Mtr Ctr	6	4/5	Y	3,3a
Siemens	200	WPL4x12RJ (x=2-4)	1	Mtr Ctr	2-4	4/5	Y	3,3a
Siemens	200	WPL6x12RJ (x=4-6)	1	Mtr Ctr	4-6	4/5	Y	3,3a
Siemens	200	WPL8612RJ	1	Mtr Ctr	6	4/5	Y	3,3a
Siemens	225	WML1x225RJ (x=1-4)	1	Ov/Un	1-4	4/5	Y	3,3a
Siemens	225	WMLx1225RJ (x=2-6)	1	Ov/Un	2-6	4/5	Y	3,3a
Siemens	225	WMLx2225RJ (x=1-4)	3	Under	1-4	7	Y	4
Siemens	225	WMLx2yz225RJ (x=2 or 4) (yz=AB, BC or CA)	3	Ov/Un	2 or 4	5	Y	3,3A
Siemens	250	WC2040B1TxR (x=1-9)	1	Under	1	4	N	1
Siemens	250	WC2040B1TxRJ (x=1-9)	1	Under	1	5	N	2
Siemens	250	WC2040B2TxRJ (x=1-9)	1	Under	1	5	N	2
Siemens	250	WCL2040B1TxRJ (x=1-9)	1	Under	1	4/5	N	1,2
Siemens	250	WCL2040B2TxRJ (x=1-9)	1	Under	1	4/5	Y	3,3a
Siemens	250	WCL2442B3TxRJ (x=1-9)	3	Under	1	7	Y	4



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Siemens	400	MC0408B1400RLTM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	MC0816B1350RLTM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	MC0816B1400RLTM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	MM0404L1400RLM	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	WML13400RJ	3	Ov/Un	1	7	Y	4
Siemens	400	WML13400RJFS	3	Ov/Un	1	7	Y	4
Siemens	400	WMLxy400RJ where (x=1-2) (y=1-2)	1	Ov/Un	1	4/5	Y	3,3a
Siemens	400	WMLxy400RJFS where (x=1- 2) (y=1-2)	1	Ov/Un	1	4/5	Y	3,3a
Siemens	600	WMK13600RJ FPL Only	1/3	Under	1	7	Y	5
Square D	100	UTZ-6R1131C-FLSQD	1	Ov/Un	6	4	N	1
Square D	100	UTZ-xR1121C-FLSQD (x=2-5)	1	Ov/Un	2-5	4	N	1
Square D	125	EZMR11y125 (y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125	EZMR11y125CU (y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125	EZMR11y125X (y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125	EZMR31y125 (y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125	EZMR31y125CU (y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125	EZMR31y125X (y=3-6)	1	Mtr Ctr	3-6	5	N	1,2
Square D	125	MPRyy125 (yy=22,33,44,55,66)	1	Ov/Un	2-6	5	N	1,2
Square D	125	UATZ-RS101C-FLSQD	1	Ov/Un	1	4	N	1 AI
Square D	125	UTZ-RS101C-FLSQD	1	Ov/Un	1	4	N	1
Square D	150	QC816F150C	1	Ov/Un	1	4/5	N	1,2
Square D	150	RC816F150C	1	Ov/Un	1	4/5	N	1,2
Square D	150	RQC150SFMG	1	Ov/Un	1	4/5	N	1,2
Square D	200	EZML11y200 (y=1-4)	1	Mtr Ctr	1-4	5	Y	1,2
Square D	200	EZML31y200 (y=2-4)	1	Mtr Ctr	2-4	5	Y	3a
Square D	200	EZML33y200 (y=1-4)	3	Mtr Ctr	1	7	Y	4
Square D	200	EZMR11y200 (y=2-4)	1	Mtr Ctr	2-4	5	N	1,2
Square D	200	EZMR11y200CU (y=2-4)	1	Mtr Ctr	2	5	N	1,2
Square D	200	EZMR11y200X (y=2-4)	1	Mtr Ctr	2	5	N	1,2
Square D	200	MPLyy200 (yy=32,43,64)	1	Ov/Un	2-4	5	Y	3
Square D	200	MPR4y200 (y=2-3)	1	Ov/Un	2-3	5	N	1,2
Square D	200	MPR64200	1	Ov/Un	4	5	N	1,2
Square D	200	MPR8y200 (y=5-6)	1	Ov/Un	5-6	5	N	1,2
Square D	200	QC12L200C	1	Ov/Un	1	4/5	N	1,2
Square D	200	QC2442M200C	1	Ov/Un	1	4/5	Y/N	1,2
Square D	200	QC816F200C	1	Ov/Un	1	4/5	N	1,2
Square D	200	RC12L200C	1	Ov/Un	1	4/5	N	1,2
Square D	200	RC200SFMG	1	Ov/Un	1	4/5	N	1,2
Square D	200	RC2040M200C	1	Ov/Un	1	4/5	N	1,2



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number		Phase	Service	Pos	Term	Bypass	Config
Square D	200	RC2M200SFMG		1	Ov/Un	1	4/5	N	1,2
Square D	200	RC816F200C		1	Ov/Un	1	4/5	N	1,2
Square D	200	RQC200SFMG		1	Ov/Un	1	4/5	N	1,2
Square D	200	UAT-H4203x-FLSQD	(x=B or T)	1	Over	1	4	Y	1 AI
Square D	200	UAT-H4213x-FLSQD	(x=C or U)	1	Ov/Un	1	4	Y	1 AI
Square D	200	UAT-H5203x-FLSQD	(x=B or T)	1	Over	1	5	Y	3,3a,3b AI
Square D	200	UAT-H5213x-FLSQD	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b AI
Square D	200	UAT-H7203x-FLSQD	(x=B or T)	3	Over	1	7	Y	4 AI
Square D	200	UAT-H7213x-FLSQD	(x=C or U)	3	Ov/Un	1	7	Y	4 AI
Square D	200	UAT-RS202B-FLSQD		1	Over	1	4	N	1 AI
Square D	200	UAT-RS212C-FLSQD		1	Ov/Un	1	4	N	1 AI
Square D	200	UAT-RS213A-FLSQD		1	Under	1	4	N	1 AI
Square D	200	UAT-RS213C-FLSQD		1	Ov/Un	1	4	N	1 AI
Square D	200	UAT-RS223A-FLSQD		1	Under	1	4	N	1 AI
Square D	200	UT-4R2352U-FLSQD		1	Ov/Un	4	4	N	1
Square D	200	UT-H4203x-FLSQD	(x=B or T)	1	Over	1	4	Y	1
Square D	200	UT-H4213x-FLSQD	(x=C or U)	1	Ov/Un	1	4	Y	1
Square D	200	UT-H5203x-FLSQD	(x=B or T)	1	Over	1	5	Y	3,3a,3b
Square D	200	UT-H5213x-FLSQD	(x=C or U)	1	Ov/Un	1	5	Y	3,3a,3b
Square D	200	UT-H7203x-FLSQD	(x=B or T)	3	Over	1	7	Y	4
Square D	200	UT-H7213x-FLSQD	(x=C or U)	3	Ov/Un	1	7	Y	4
Square D	200	UT-RS202B-FLSQD		1	Over	1	4	N	1
Square D	200	UT-RS212C-FLSQD		1	Ov/Un	1	4	N	1
Square D	200	UT-RS213A-FLSQD		1	Under	1	4	N	1
Square D	200	UT-RS213C-FLSQD		1	Ov/Un	1	4	N	1
Square D	200	UT-RS223A-FLSQD		1	Under	1	4	N	1
Square D	200	UT-xR2332U-FLSQD	(x=2-3)	1	Ov/Un	2-3	4	N	1
Square D	200	UT-xR2392UU-FLSQD	(x=5-6)	1	Ov/Un	5-6	4	N	1
Square D	225	EZML11x225	(x=1-4)	1	Mtr Ctr	1-4	5	Y	1,2
Square D	225	EZML31x225	(x=2-4)	1	Mtr Ctr	2-4	5	Y	3a
Square D	225	EZML33x225	(x=1-4)	3	Mtr Ctr	1	7	Y	4
Square D	225	EZMR11x200X	(x=2-4)	1	Mtr Ctr	2	5	N	1,2
Square D	225	EZMR11x225	(x=2-5)	1	Mtr Ctr	2-5	5	N	1,2
Square D	225	EZMR11x225CU	(x=2-5)	1	Mtr Ctr	2-5	5	N	1,2
Square D	225	EZMR31x225	(x=2-5)	1	Mtr Ctr	2-5	5	N	1,2
Square D	400	1008836SQD		1	Ov/Un	1	4	Y	1
Square D	400	1008837SQD		1	Ov/Un	1	4	Y	1 AI
Square D	400	EZML31y400	(y=1-2)	1	Mtr Ctr	1-2	5	Y	3a
Square D	400	EZML33y400	(y=1-2)	3	Mtr Ctr	1-2	7	Y	4



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Square D	400	QU12L400xL (x = C or S)	1	Under	1	4/5	Y	3
Square D	400	QU816D400SL	1	Under	1	4/5	Y	3
Square D	400	UAT-H4300T-FLSQD	1	Over	1	4	Y	1 AI
Square D	400	UAT-H5300T-FLSQD	1	Over	1	5	Y	3,3a,3b AI
Square D	400	UAT-H5330U-FLSQD	1	Ov/Un	1	5	Y	3,3a,3b AI
Square D	400	UAT-H7300T-FLSQD	3	Over	1	7	Y	4 AI
Square D	400	UAT-H7330U-FLSQD	3	Ov/Un	1	7	Y	4 AI
Square D	400	UT-H4300T-FLSQD	1	Over	1	4	Y	1
Square D	400	UT-H5300T-FLSQD	1	Over	1	5	Y	3,3,3ba
Square D	400	UT-H5330U-FLSQD	1	Ov/Un	1	5	Y	3,3a,3b
Square D	400	UT-H7300T-FLSQD	3	Over	1	7	Y	4
Square D	400	UT-H7330U-FLSQD	3	Ov/Un	1	7	Y	4
Talon	100	MP04061100R	1	Under	1	4	N	1
Talon	100	MP04061100R2	1	Under	2	4	N	1
Talon	100	MPS0406B1100R	1	Under	1	4	N	1
Talon	100	MPS0406B1100R2	1	Under	2	4	N	1
Talon	100	UAB111-XG	1	Ov/Un	1	4	N	1
Talon	100	UAT111-XGF	1	Over	1	4/5	N	1,2
Talon	100	UAT131-XGF	1	Over	1	4/5	N	1,2 AI
Talon	100	UAX411-XGF (X=2-6)	1	Ov/Un	2-6	4	N	1
Talon	125	49205-025F	1	Over	1	5	Y	3a
Talon	125	49207-025F	3	Over	1	7	Y	4
Talon	125	49305-025F	1	Over	1	5	Y	3a
Talon	125	49307-025F	3	Over	1	7	Y	4
Talon	125	MP0406B1125R	1	Under	1	4	N	1
Talon	125	MP0406B1125R2	1	Under	2	4	N	1
Talon	125	MPS0406B1125R	1	Under	1	4	N	1
Talon	125	MPS0406B1125R2	1	Under	2	4	N	1
Talon	125	TLxxRT (x=brkr/recpt config.)	1	Over	1,2	4/5	N	1,2
Talon	125	TLxxxRC (x=brkr/recpt config.)	1	Under	1	4/5	N	1,2
Talon	125	TLxxxRM (x=brkr/recpt config.)	1	Un-Ped	1,2	4/5	N	1,2
Talon	125	TLxxxRP-F (x=brkr/recpt config.)	1	Un-Ped	1,2	4/5	N	1,2
Talon	125	UAT111-OGF	1	Over	1	4	N	1
Talon	125	UAT111-XMF	1	Under	1	5	N	2
Talon	125	WTG4x11RJ (X=5-6)	1	Ov/Un	5-6	5	N	2
Talon	125	WTG5411RJ	1	Ov/Un	4	5	N	2
Talon	125	WTG6x11RJ (X=5-6)	1	Ov/Un	5-6	5	N	2
Talon	125	WTGxx11RJ (X=2-4)	1	Ov/Un	2-4	5	N	2
Talon	150	MP0406B1150R	1	Under	1	4	N	1



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Talon	150	MP0406B1150R2	1	Under	2	4	N	1
Talon	150	MPS0406B1150R	1	Under	1	4	N	1
Talon	150	MPS0406B1150R2	1	Under	2	4	N	1
Talon	150	UAB417-150	1	Ov/Un	1	4/5	N	1,2
Talon	200	40005-01F	1	Over	1	5	Y	3,3a
Talon	200	40007-01F	3	Over	1	7	Y	4
Talon	200	40404-025F	1	Ov/Un	1	4	N	1
Talon	200	40405-015F	1	Ov/Un	1	5	Y	3,3a
Talon	200	40405-025F	1	Ov/Un	1	5	Y	3,3a
Talon	200	40405x-223F (x=2-6)	1	Ov/Un	2-6	5	Y	3a
Talon	200	40407-015F	3	Ov/Un	1	7	Y	4
Talon	200	40407-025F	3	Ov/Un	1	7	Y	4
Talon	200	40407x-223F (x=2-6)	3	Ov/Un	2-6	7	Y	4
Talon	200	41005-01F	1	Over	1	5	Y	3,3a
Talon	200	41007-01F	3	Over	1	7	Y	4 AI
Talon	200	41405-025F	1	Ov/Un	1	5	Y	3,3a AI
Talon	200	41407-025F	3	Ov/Un	1	7	Y	4 AI
Talon	200	46705-025F	1	Ov/Un	1	5	Y	3a
Talon	200	46707-025F	3	Ov/Un	1	7	Y	4
Talon	200	46805-025F	1	Ov/Un	1	5	Y	3a
Talon	200	46807-025F	3	Ov/Un	1	7	Y	4
Talon	200	LG0408B1200RT	1	Ov/Un	1	4	N	1
Talon	200	LG0606L1200R or RA	1	Ov/Un	1	4/5	N	1, 2 AI
Talon	200	MP0406B1200R	1	Under	1	4	N	1
Talon	200	MP0406B1200R2	1	Under	2	4	N	1
Talon	200	MP0406L1200R	1	Under	1	4	N	1
Talon	200	MP0406L1200R2	1	Under	2	4	N	1
Talon	200	MPS0406B1200R	1	Under	1	4	N	1
Talon	200	MPS0406B1200R2	1	Under	2	4	N	1
Talon	200	UA27x6-ZGF (x=1 or 3)	1	Ov/Un	2	4	N	1 AI
Talon	200	UA37x7-ZGF (x=1 or 3)	1	Ov/Un	3	4	N	1 AI
Talon	200	UA47x9-ZGF (x=1 or 3)	1	Ov/Un	4	4	N	1 AI
Talon	200	UA57x9-MGF (x=1 or 3)	1	Ov/Un	5	4	N	1 AI
Talon	200	UA67x9-MGF (x=1 or 3)	1	Ov/Un	6	4	N	1 AI
Talon	200	UAB417-200	1	Ov/Un	1	4/5	N	1,2
Talon	200	UAB417-XPG	1	Ov/Un	1	4	N	1
Talon	200	UAS877-PGF	1	Under	1	4	N	1
Talon	200	UAT317-OGF	1	Over	1	4/5	N	1,2
Talon	200	UAT337-OGF	1	Over	1	4/5	N	1,2 AI



Approved Metering Equipment Enclosure List

Revised
2/5/2016

Manufacturer	Amps	Catalog Number	Phase	Service	Pos	Term	Bypass	Config
Talon	200	UAT417-PGF	1	Under	1	4/5	N	1,2
Talon	200	UAT417-XGF	1	Ov/Un	1	4/5	N	1,2
Talon	200	UAT437-PGF	1	Under	1	4/5	N	1,2 AI
Talon	200	UAT437-XGF	1	Ov/Un	1	4/5	N	1,2 AI
Talon	200	UAT777-XGF	1	Ov/Un	1	4	N	1
Talon	200	UAx711-ZGF (x=2-4)	1	Ov/Un	2-4	4	N	1
Talon	200	UAx715-MGF (x=5-6)	1	Ov/Un	5-6	4	N	1
Talon	200	UAx71y-ZGF (x=2-4) (y=4-5)	1	Ov/Un	2-4	4	N	1
Talon	225	WTG10612RJ	1	Ov/Un	6	5	N	2
Talon	225	WTG4x12RJ (X=2-4)	1	Ov/Un	2-4	5	N	2
Talon	225	WTG6x12RJ (X=4-6)	1	Ov/Un	4-6	5	N	2
Talon	225	WTG8612RJ	1	Ov/Un	6	5	N	2
Talon	225	WTGL10612RJ	1	Ov/Un	6	5	Y	3a
Talon	225	WTGL4x12RJ (x=2-4)	1	Ov/Un	2-4	5	Y	3a
Talon	225	WTGL6x12RJ (x=4-6)	1	Ov/Un	4-6	5	Y	3a
Talon	225	WTGL8612RJ	1	Ov/Un	6	5	Y	3a
Talon	320	40905-02FL	1	Ov/Un	1	5	Y	3a
Talon	320	46905-02FL	1	Ov/Un	1	5	Y	3a
Talon	320	47005-02FL	1	Ov/Un	1	5	Y	3a
Talon	320	47205-02FL	1	Ov/Un	1	5	Y	3a
Talon	320	47205-82FL	1	Ov/Un	1	5	Y	3a
Talon	320	47305-02FL	1	Ov/Un	1	5	Y	3a
Talon	320	47305-82FL	1	Ov/Un	1	5	Y	3a
Talon	320	47407-02FL	3	Under	1	7	Y	4
Talon	400	41105-02FL	1	Ov/Un	1	4/5	Y	3,3a AI
Talon	400	44707-02FL	3	Ov/Un	1	7	Y	4
Talon	400	47705-02FL	1	Ov/Un	1	4/5	Y	3,3a
Talon	400	49005-02FL	1	Ov/Un	1	4/5	Y	3,3a
Talon	400	49007-02FL	3	Ov/Un	1	7	Y	4
Talon	400	49105-02FL	1	Ov/Un	1	4/5	Y	3,3a AI
Talon	400	49107-02FL	3	Ov/Un	1	7	Y	4 AI
Talon	400	MC3042B1400SDL	1	Ov/Un	1	4	N	1
Talon	600	9817-9526 (Requires Ridged Lugs) FPL ONLY	1,3	Ov/Un	1	7	Y	5
Talon	600	9817-9527 (Requires Ridged Lugs) FPL ONLY	1,3	Ov/Un	1	7	Y	5 AI



Florida Power & Light

Approved Transformer Rated Equipment

3/09/2016

Note: Instrument Transformer Rated Meter Sockets and Cabinets on this list are only approved for use in the FPL Service Area. Before purchase, please contact your FPL Representative. Instrument Transformer Metering must be approved by FPL.

INSTRUMENT RATED METER SOCKETS

Manufacture	Amps	Catalog Number	Phase	Service	Pos	Term	Test	Switch	Config
Brooks Utility Produ	20	602U3010C13-387 (TUV Steel)	3	Ov/Un	1	13	Y		6-12
Brooks Utility Produ	20	602U3010C6-388 (Q6 Steel)	1	Ov/Un	1	6	Y		6-12
Brooks Utility Produ	20	605U8010C13-934 (TUV Steel Snap 2)	3	Ov/Un	1	13	Y		6-12
Brooks Utility Produ	20	652U3010C13-387 (TUV Alum)	3	Ov/Un	1	13	Y		6-12
Brooks Utility Produ	20	652U3010C6-388 (Q6 Alum)	1	Ov/Un	1	6	Y		6-12
Brooks Utility Produ	20	655U8010C13-934 (TUV Alum Snap 2)	3	Ov/Un	1	13	Y		6-12
Talon	20	9837-0422 (PTS-6 Aluminum)	1	Ov/Un	1	6	Y		6-12
Talon	20	9837-0423 (PTS-6 Steel)	1	Ov/Un	1	6	Y		6-12
Talon	20	9837-0424 (PTS-13 Alum)	3	Ov/Un	1	13	Y		6-12
Talon	20	9837-0425 (PTS-13 Steel)	3	Ov/Un	1	13	Y		6-12
Anchor	20	RTSA13-13-FP&L (Alum)	3	Ov/Un	1	13	Y		6-12
Anchor	20	RTSA6-73-FP&L (Alum)	1	Ov/Un	1	6	Y		6-12
Anchor	20	RTSS13-13-FP&L (Steel)	3	Ov/Un	1	13	Y		6-12
Anchor	20	RTSS6-73-FP&L (Steel)	1	Ov/Un	1	6	Y		6-12
Cooper B-Line	20	ST02063N1AL1F (Q6 ALUM)	1	Ov/Un	1	6	Y		6-12
Cooper B-Line	20	ST02063N1GR1F (Q6 STEEL)	1	Ov/Un	1	6	Y		6-12
Cooper B-Line	20	ST02133N1AL1F (TUV ALUM)	3	Ov/Un	1	13	Y		6-12
Cooper B-Line	20	ST02133N1GR1F (TUV STEEL)	3	Ov/Un	1	13	Y		6-12
Milbank	20	UAPC4511 (Q6 Alum)	1	Ov/Un	1	6	Y		6-12
Milbank	20	UAPC4512 (TUV Alum)	3	Ov/Un	1	13	Y		6-12
Milbank	20	UC4511 (Q6 Steel)	1	Ov/Un	1	6	Y		6-12
Milbank	20	UC4512 (TUV Steel)	3	Ov/Un	1	13	Y		6-12



Florida Power & Light

Approved Transformer Rated Equipment

3/09/2016

Note: Instrument Transformer Rated Meter Sockets and Cabinets on this list are only approved for use in the FPL Service Area. Before purchase, please contact you FPL Representative. Instrument Transformer Metering must be approved by FPL.

WALL MOUNTED TRANSFORMER CABINETS

FPL will no longer accept Steel or Stainless TC-3 and TC-5 cabinets with pull-off covers. Only Aluminum pull-off covers are allowed. All Steel and Stainless TC-3 and TC-5 cabinets must have hinged doors. Contact Meter Engineering for correct part number and approval.

***Max number of conductors is the TOTAL number of conductors ENTERING the cabinet plus the number EXITING**

Manufacture	Catalog Number (Material - H"xW"xD")	Phase	Max # of Conduits (Total # In and Out)	*Max # and Size of Conductors	Config
Austin Co.	FPL-C-TC1-SS (Custom Stainless - As Required)	3	As Req.	As Required	9
Austin Co.	FPL-S-TC3-GRAY (TC-3 Galv - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Austin Co.	FPL-C-TC1-GRAY (Custom Steel - As Required)	3	As Req.	As Required	9
Austin Co.	FPL-C-TC1 (Custom Alum - As Required)	3	As Req.	As Required	9
Austin Co.	FPL-S-TC5 SS (TC-5X SS - 46 x 30 x 14.5)	3	8 - 4"	16-600C or 16-400A	8
Austin Co.	FPL-S-TC5-GRAY (TC-5X Galv - 46 x 30 x 14.5)	3	8 - 4"	16-600C or 16-400A	8
Austin Co.	FPL-S-TC3 (TC-3 Alum - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Austin Co.	FPL-S-TC3 SS (TC-3 SS - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Austin Co.	FPL-S-TC5 (TC-5X Alum - 46 x 30 x 14.5)	3	8 - 4"	16-600C or 16-400A	8
Brooks Utility Produ	561U3801 (TC-3 Alum - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Brooks Utility Produ	561U3815G (TC-3 Alum - 34 x 32 x 12)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Brooks Utility Produ	561U3802 (TC-5X Alum - 46 x 30 x 14.5)	3	8 - 4"	16-600C or 16-400A	8
C&I Enclosures	C-343212FPLHG-TC3 (TC-3 Alum, Hinged Cover	1,3	4 - 4"	8 - 600C or 8 - 400A	7
C&I Enclosures	C-343212FPLA-TC3 (TC-3 Alum - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
C&I Enclosures	C-463014.50FPLA-TC5 (TC-5 Alum - 46 x 30 x 14.	3	8 - 4"	16-600C or 16-400A	8
C&I Enclosures	C-463014.50FPLHG-TC5 (TC-5 Alum, Hinged Cov	3	8 - 4"	16-600C or 16-400A	8
Cooper B-Line	304614.5 RTCT1F AL (TC-5X Alum - 46 x 30 x 14	3	8 - 4"	16-600C or 16-400A	8



Florida Power & Light

Approved Transformer Rated Equipment

3/09/2016

Note: Instrument Transformer Rated Meter Sockets and Cabinets on this list are only approved for use in the FPL Service Area. Before purchase, please contact your FPL Representative. Instrument Transformer Metering must be approved by FPL.

Cooper B-Line	323410 RTCT1F AL (TC-3 Alum - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Cooper B-Line	323410 RTCT1F (TC-3 Steel - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Cooper B-Line	323412 RTCT1F AL (TC-3 Alum - 34 x 32 x 12)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Cooper B-Line	323412 RTCT1F (TC-3 Steel - 34 x 32 x 12)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Cooper B-Line	304614.5 RTCT1F (TC-5X Steel - 46 x 30 x 14.5)	3	8 - 4"	16-600C or 16-400A	8
E-Box	343212REPL/FPL (TC-3 Steel, Left-hand hinged - 3	1,3	4 - 4"	8 - 600C or 8 - 400A	7
E-Box	A463014.50RB/FPLTC5 (TC-5 Alum - 46 x 30 x 1	3	8 - 4"	16 - 600C or 16 - 400A	8
E-Box	A463014.50REPL/FPL (TC-5 Steel, Left-hand hing	3	8 - 4"	16 - 600C or 16 - 400A	8
E-Box	463014.50REPLRH/FPL (TC-5 Steel, Right-hand hi	3	8 - 4"	16 - 600C or 16 - 400A	8
E-Box	343212REPL/RH/FPL (TC-3 Steel, Right-hand hing	1,3	4 - 4"	8 - 600C or 8 - 400A	7
E-Box	A343212RB/FPLTC3 (TC-3 Alum - 34 x 32 x 12)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Hoffman	TC3 (TC-3 Steel - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Hoffman	TC5X (TC-5X Steel - 46 x 30 x 16)	3	As Req.	As Required	9
Hoffman	TC5XSS (TC-5X Stainless - 46 x 30 x 16)	3	As Req.	As Required	9
Hoffman	TC5XAL (TC-5X Alum - 46 x 30 x 16)	3	As Req.	As Required	9
Hoffman	TC5 (TC-5 Steel - 46 x 30 x 14-1/2)	3	8 - 4"	16-600C or 16-400A	8
Hoffman	TC5AL (TC-5 Alum - 46 x 30 x 14-1/2)	3	8 - 4"	16-600C or 16-400A	8
Hoffman	TC3SS (TC-3 Stainless - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Hoffman	TC3AL (TC-3 Alum - 34 x 32 x 10)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Hoffman	TC5SS (TC-5 Stainless - 46 x 30 x 14-1/2)	3	8 - 4"	16-600C or 16-400A	8
Milbank	323412-SC3RA-SP (TC-3 Alum - 28 x 30 x 12)	1,3	4 - 4"	8 - 600C or 8 - 400A	7
Milbank	304614-SC3RA-SP (TC-5 Alum - 46 x 30 x 14.5)	1,3	4 - 4"	16-600C or 16-400A	8



Florida Power & Light

Approved Transformer Rated Equipment

3/09/2016

Note: Instrument Transformer Rated Meter Sockets and Cabinets on this list are only approved for use in the FPL Service Area. Before purchase, please contact you FPL Representative. Instrument Transformer Metering must be approved by FPL.

WEATHERHEAD MOUNTED TRANSFORMER CABINETS

****Note: These cabinets are NOT UL LISTED and may not be utilized in jurisdictions where listing is a requirement**

Manufacture	Catalog Number (Material)	Phase	Approx Size (H" x W" x D")	Config
Brooks Utility Produ	508-5127** (TCWM - Steel)	1,3	27-1/2 x 6 1/2 x 6 1/2	10
Brooks Utility Produ	558-5127** (TCWM - Alum)	1,3	27-1/2 x 6 1/2 x 6 1/2	10

PRIMARY PADMOUNTED TRANSFORMER CABINETS

Manufacture	Catalog Number (Material)	Phase	Voltage	Max Amps	Approx Size (H"xW"xD")	Config
Brooks Utility Produ	SKA270192-1AL (Aluminum)	3	25kv	1x200	54 x 72 x 54	11
Shallbetter	SPMD-32522-66-AL-FPL (Aluminum)	3	25kv	2x600	54 x 72 x 72	11
Shallbetter	SPMD-32522-22-AL-FPL (Aluminum)	3	25kv	2x200	54 x 72 x 72	11
Shallbetter	SPMD-32522-66-SS-FPL (Stainless Steel)	3	25kv	2x600	54 x 72 x 72	11
Shallbetter	SPMD-32522-22-SS-FPL (Stainless Steel)	3	25kv	2x200	54 x 72 x 72	11
SPS	DFPM -3252222-AL-FPL (Aluminum)	3	25kv	2x600	54 x 72 x 72	11
SPS	DFPM -3252222-AL-FPL (Aluminum)	3	25kv	2x600	54 x 72 x 72	11
SPS	DFPM -3252266-AL-FPL (Aluminum)	3	25kv	2x200	54 x 72 x 72	11
SPS	DFPM -3252222-SS-FPL (Stainless Steel)	3	25kv	2x600	54 x 72 x 72	11
SPS	DFPM -3252266-SS-FPL (Stainless Steel)	3	25kv	2x200	54 x 72 x 72	11

METERING EQUIPMENT CABINETS

Manufacture	Catalog Number (Material)	Useage	Type	Approx Size (H"xW"xD")	Config
Austin Co.	FPL-EE-X-SS (SJB-CX Stainless)	UTILITY	X-LARGE	46 x 36 x 14	12
Austin Co.	FPL-UTB-A-GRAY (UTB Steel)	UTILITY	-	12 x 8 x 3-3/4	12
Austin Co.	FPL-UTB-A-SS (UTB Stainless)	UTILITY	-	12 x 8 x 3-3/4	12



Florida Power & Light

Approved Transformer Rated Equipment

3/09/2016

Note: Instrument Transformer Rated Meter Sockets and Cabinets on this list are only approved for use in the FPL Service Area. Before purchase, please contact your FPL Representative. Instrument Transformer Metering must be approved by FPL.

Austin Co.	FPL-EE-M (SJB-28 Alum)	UTILITY	MED	28 x 30 x 14	12
Austin Co.	FPL-EE-X-GRAY (SJB-CX Steel)	UTILITY	X-LARGE	46 x 36 x 14	12
Austin Co.	FPL-EE-X (SJB-CX Alum)	UTILITY	X-LARGE	46 x 36 x 14	12
Austin Co.	FPL-EE-L-GRAY (SJB-C Steel)	UTILITY	LARGE	36 x 36 x 14	12
Austin Co.	FPL-EE-L-SS (SJB-C Stainless)	UTILITY	LARGE	36 x 36 x 14	12
Austin Co.	FPL-EE-L (SJB-C Alum)	UTILITY	LARGE	36 x 36 x 14	12
Austin Co.	FPL-EE-M-GRAY (SJB-28 Steel)	UTILITY	MED	28 x 30 x 14	12
Austin Co.	FPL-EE-M-SS (SJB-28 Stainless)	UTILITY	MED	28 x 30 x 14	12
Austin Co.	FPL-UTB-A (UTB Alum)	UTILITY	-	12 x 8 x 3-3/4	12
Brooks Utility Produ	574U3805 (SJB-C Alum)		LARGE	36 x 36 x 14	12
Brooks Utility Produ	557U3807 (SJB-28 Alum)		MED	30 x 28 x 14	12
Brooks Utility Produ	574U3807 (SJB-28 Alum)		MED	30 x 28 x 14	12
Brooks Utility Produ	507U3807 (SJB-28 Steel)		MED	30 x 28 x 14	12
Brooks Utility Produ	511U3811 (UTB Steel)	UTILITY	-	12 x 8 x 3-3/4	12
Brooks Utility Produ	557U3806 (SJB-CS Alum)		X-LARGE	46 x 36 x 14	12
Brooks Utility Produ	524U3807 (SJB-28 Steel)		MED	30 x 28 x 14	12
Brooks Utility Produ	566U5183-FPL (UMC)	UTILITY	-	20 x 16 x 6	13
Brooks Utility Produ	557U3805 (SJB-C Alum)		LARGE	36 x 36 x 14	12
Brooks Utility Produ	561U3811 (UTB Alum)	UTILITY	-	12 x 8 x 3-3/4	12
Brooks Utility Produ	524U3806 (SJB-CS Steel)		X-LARGE	46 x 36 x 14	12
Brooks Utility Produ	507U3806 (SJB-CS Steel)		X-LARGE	46 x 36 x 14	12
Brooks Utility Produ	524U3805 (SJB-C Steel)		LARGE	36 x 36 x 14	12
Brooks Utility Produ	507U3805 (SJB-C Steel)		LARGE	36 x 36 x 14	12
Brooks Utility Produ	574U3806 (SJB-CS Alum)		X-LARGE	46 x 36 x 14	12
Milbank	302814-CT3RS-SP (SJB-28 Stainless)	UTILITY	MED	30 x 28 x 14	12



Florida Power & Light

Approved Transformer Rated Equipment

3/09/2016

Note: Instrument Transformer Rated Meter Sockets and Cabinets on this list are only approved for use in the FPL Service Area. Before purchase, please contact your FPL Representative. Instrument Transformer Metering must be approved by FPL.

Milbank	302814-CT3R-SP (SJB-28 Steel)	UTILITY	MED	30 x 28 x 14	12
Milbank	363614-CT3RA-SP (SJB-C Alum)	UTILITY	LARGE	36 x 36 x 14	12
Milbank	363614-CT3RS-SP (SJB-C Stainless)	UTILITY	LARGE	36 x 36 x 14	12
Milbank	363614-CT3R-SP (SJB-C Steel)	UTILITY	LARGE	36 x 36 x 14	12
Milbank	302814-CT3RA-SP (SJB-28 Alum)	UTILITY	MED	30 x 28 x 14	12